

Floor/ceiling fire and acoustic rated systems

Product	BPB Plasterboard
System	Timber floor/ceiling system
System Number	TGDF30a
Fire Resistance Rating	30/30/30
Plasterboard System	1 Layer 13mm BPB Firestop

Framing

Flooring joists are Radiata pine and shall comply with NZS 3604:1990 or NZS 3603:1993. Joists shall be a minimum size of 250mm x 50mm and spaced at no more than 600mm centres. Blocking should be fixed at a maximum of 1800mm centres including the edges of the floor/ceiling.

Flooring

Flooring shall be nominal 20mm thick particle board or 19mm thick flooring grade plywood and fixed as per manufacturers instructions. Nogs fixed on flat to receive edges of particle board should be minimum 100 x 50mm.

Steel Furring Channel


Steel furring channels separately designed for serviceability criteria, are spaced at a maximum of 600mm centres and fixed to the joists with direct fix clips at a maximum of 1200mm centres.

Lining

One layer of 13.0mm BPB Firestop fixed directly across the furring channels. All butt joints must occur on furring channels.

Fixing

Ceiling sheets shall be fixed at 200mm centres along each furring channel and to end butt joints using single fastener screw fixings. Stagger all sheet joints between layers.



Corners

The internal joint between ceiling and walls shall be protected by plasterboard coving or a tape reinforced corner.

Jointing

All fastener heads stopped and all sheet joints reinforced with paper jointing tape to outside layer only and stopped in accordance with AS/NZS 2589.1.

